



NOTES:

1. ACCEPTABLE REDUCED PRESSURE ZONE ASSEMBLIES:
WATTS 009M2QT OR M3QT, WATTS 909M1QT, WILKINS 975XL, WILKINS 375, APOLLO (CONBRACO) RP4A, OR APOLLO (CONBRACO) 40-200
2. RPZ REQUIRED FOR UNDERGROUND SPRINKLERS LOCATED ON THE EXTERIOR OF THE HOME.
3. SWIMMING POOLS SHALL HAVE A TESTABLE DOUBLE CHECK VALVE ASSEMBLY.
4. EXTERIOR HOSE BIBS SHALL HAVE A VACUUM BREAKER.
5. ALL PIPE & FITTINGS FROM FLARED ANGLE VALVE THROUGH LAST BALL VALVE SHALL BE BRASS THREADED.

PLAN

ELEVATION

<p>960 Fifth Avenue Coraopolis, PA 15108 www.niraengineers.com mail@niraengineers.com</p>	
DR. BY: C.J.R.	DATE: 11-21-2013
SHT. NO. 1 OF 1	SCALE: N.T.S.

THE MUNICIPAL AUTHORITY OF
THE TOWNSHIP OF ROBINSON

TYPICAL RESIDENTIAL
DUAL METER INSTALLATION